



Compliance Schedule Details:

SS 1 – Automatic Systems for Fire Suppression (e.g. Sprinkler System)

Please provide the following information with your Building Consent Application - Form 2

If you need help to complete this form, consult the system provider or an IQP who is registered for the system above.

Applicant Name:	Building Name:
Site Address:	Installation provider: (if known)
.....
Existing Compliance Schedule Number(s): (if applicable)	Risk / Purpose group:
.....	Fire Hazard Category:
.....	Total Occupant Load:

SPECIFIED SYSTEM DESCRIPTION (address those items that apply)

Specified systems: Existing New Modified Removed

Type: Type 6 or Type 7

Gas flood fire suppression system installed within a building for computer equipment protection.

Other: [specify]

Location Plan for specified systems and records is attached: YES NO

No.	Equipment location	Make (Main components)	Model
1			
2			
3			
4			

If needed continue the list on another sheet of paper

STANDARDS (address those items that apply)

(Refer to MBIE [CS Handbook 2014](#))

Specifically, designed solutions do not apply if the system has been installed against a specific Standard(s) / document.

- Performance / installation:**
- NZS 4541:2020 Automatic fire sprinkler systems.
 - NZS 4541:2013 Automatic fire sprinkler systems.
 - NZS 4541:2007 Automatic fire sprinkler systems.
 - NZS 4541:2003 Automatic fire sprinkler systems.
 - NZS 4541:1996 Automatic fire sprinkler systems.
 - NZS 4541:1987 Automatic fire sprinkler systems.
 - NZS 4541P:1972 NZ rules for automatic fire sprinkler installations.
 - NZS 4515:2009 Fire sprinkler systems for life safety in sleeping occupancies (up to 2000m²)
 - NZS 4515:2003 Fire sprinkler systems for residential occupancies.
 - NZS 4515:1995 Fire sprinkler systems for residential occupancies (including private dwellings)
 - NZS 4515:1990 Residential fire sprinkler systems.
 - Specifically, designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided).
 - Other:

continue on the next page

Inspections:	<input type="checkbox"/> NZS 4541:2020 Part 12, Clause 12.3 to 12.4 <input type="checkbox"/> NZS 4541:2013 Part 12, Clause 1203 to 1204 <input type="checkbox"/> NZS 4515:2009 Part 8, Clause 8.2 <input type="checkbox"/> AS 1851:2012 Sections 1 to 14 <input type="checkbox"/> AS ISO 14520.1:2009 Part 9 <input type="checkbox"/> Specifically, designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided) <input type="checkbox"/> Other:
Maintenance:	<input type="checkbox"/> NZS 4541:2020 Part 12, Clause 12.1 to 12.7 <input type="checkbox"/> NZS 4541:2013 Part 12, Clause 1201 to 1207 <input type="checkbox"/> NZS 4515:2009 Part 8 <input type="checkbox"/> AS 1851:2012 Sections 1 to 14 <input type="checkbox"/> AS ISO 14520.1:2009 Part 9 <input type="checkbox"/> Specifically, designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided) <input type="checkbox"/> Other:
INSPECTIONS, MAINTENANCE AND REPORTING (address those items that apply)	
Minimum inspection and maintenance procedures:	Planned preventative inspection, maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection Standard/document, to ensure the system will operate as required in the event of a fire.
Equipment requiring weekly maintenance:	<input type="checkbox"/> Building contains Diesel Fire Pump <input type="checkbox"/> Building contains an Electric Fire pump without an alarm
Inspection & Maintenance - frequency and responsibility:	Depending on the type of installation and its performance standard/document: <input type="checkbox"/> Specifically, designed solutions: by IQP only <input type="checkbox"/> Standard /Standard /another document: <input type="checkbox"/> Monthly: by IQP only <input type="checkbox"/> Annually: by IQP only
Inspections & Maintenance:	Annual Inspection: <input type="checkbox"/> The system is connected to the building's emergency warning system therefore testing of the interface between the two systems will be carried out annually. <input type="checkbox"/> The system is NOT connected to the building's emergency warning system
Reporting:	The owner will keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. These will be recorded in the On-Site Log Book, which will remain on the premises with the most recent compliance schedule, and as a minimum include: <ul style="list-style-type: none"> • Details of any inspection, test or preventative maintenance carried out, including dates, works undertaken, faults found, remedies applied and the person who performed the work. • Form 12A provided annually by the IQP