



Compliance Schedule Details: SS 8/1 – Passenger Carrying Lifts

Please provide the following information with your Building Consent Application - Form 2

(If you need help to complete this form, consult the system provider or an IQP who is registered for the system above)

| | |
|---|---|
| Applicant Name: | Building Name: |
| Site Address: | Installation provider: (if known) |
| | |
| Existing Compliance Schedule Number(s): (if applicable) | Risk / Purpose group: |
| | Fire Hazard Category: |
| | Total Occupant Load: |

SPECIFIED SYSTEM DESCRIPTION (address those items that apply)

Specified systems: Existing New Modified Removed

Type:

High speed elevator in a commercial office building: Electric or Hydraulic

Platform lift providing access for a person with disabilities: Electric or Hydraulic

Location Plan for specified systems and records is attached: YES NO

| No. | Equipment location | Make (Main components) | Model |
|-----|--------------------|------------------------|-------|
| 1 | | | |
| 2 | | | |

If needed continue the list on another sheet of paper

STANDARDS (address those items that apply)

Specifically, designed solutions do not apply if the system has been installed against a specific Standard(s) / document.

Performance / installation:

- NZS 4332:1997 Non-domestic passenger and goods lifts; as modified by D2/AS1 (Second Edition, Amendment 6,7 and 8)
- NZS 4332P:1994 Non-domestic passenger and goods lifts.
- NZS 4334:2012 Platform lifts and low-speed lifts
- AS/NZS 1735.18:2002 Lifts, escalators and moving walks - Part 18: Passenger lifts for private residence - Automatically controlled
- AS 1735.1-2001 Lifts, escalators and moving walks - Part 1: General requirements
- AS 1735.7-1998 Lifts, escalators and moving walks - Part 7: Stairway lifts
- BS EN 81-20:2020 Safety rules for the construction and installation of lifts. Lifts for the transport of persons and goods. Part 20: Passenger and goods passenger lifts
- BS EN 81-20:2014 Safety rules for the construction and installation of lifts. Lifts for the transport of persons and goods. Part 20: Passenger and goods passenger lifts; as modified by D2/AS1 (Second Edition, Amendment 7)
- BS EN 81-1:1998 +A3:2009 Safety rules for the construction and installation of lifts. Electric lifts
- BS 5655-1:1986 Lifts and service lifts. Part 1: Safety rules for the construction and installation of electric lifts
- BS 5655-1:1979 Lifts and service lifts. Safety rules for the construction and installation of electric lifts.
- EN 81-1:1977 Lifts and service lifts. Safety rules for the construction and installation of electric lifts.
- BS 2655-1:1970 Specification for lifts, escalators, passenger conveyors and paternosters. General requirements for electric, hydraulic and hand-powered lifts.
- Specifically, designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided)
- Other:

| | | |
|--|---|--|
| Inspections: | <input type="checkbox"/> NZS 4332:1997 – Part 4 <input type="checkbox"/> NZS 4334:2012 – Appendix A <input type="checkbox"/> BS EN 81-1:1998 +A3:2009 (Electric Lift) <input type="checkbox"/> BS EN 81-2:1998 Safety rules for the construction and installation of lifts - Part 2: Hydraulic lifts <input type="checkbox"/> Ministry of Transport: 1985 Rules for Power Lifts Not Exceeding 750 Watts (1 H.P) <input type="checkbox"/> Ministry of Transport: 1989 Power lift rules | <input type="checkbox"/> Specifically, designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided) <input type="checkbox"/> Other: |
| Maintenance: | <input type="checkbox"/> NZS 4332:1997 – Part 4 <input type="checkbox"/> NZS 4334:2012 – Appendix A <input type="checkbox"/> BS EN 81-1:1998 +A3:2009 (Electric Lift) <input type="checkbox"/> BS EN 81-2:1998 Safety rules for the construction and installation of lifts - Part 2: Hydraulic lifts <input type="checkbox"/> Ministry of Transport: 1985 Rules for Power Lifts Not Exceeding 750 Watts (1 H.P) <input type="checkbox"/> Ministry of Transport: 1989 Power lift rules | <input type="checkbox"/> Specifically, designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided) <input type="checkbox"/> Other: |
| INSPECTIONS, MAINTENANCE AND REPORTING (address those items that apply) | | |
| Minimum inspection and maintenance procedures: | Regular inspection and testing and planned preventative maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection standard/document to ensure safe and suitable use and that the system will operate as required. | |
| Inspection frequency and responsibility: | Depending on the type of installation and its performance standard/document: <input type="checkbox"/> Specifically, designed solutions: by IQP only <input type="checkbox"/> Standard /other document: Annually by IQP only | |
| Inspections: <i>Machinery Spaces</i> | <ul style="list-style-type: none"> • Visual inspection of machine beams and supports • Check security of machine room door • Clean the machinery space and clear out any rubbish • Check that lighting in the machinery space functions • Check ventilation in machine room functions • Check the condition of the controller • Check the governor and any position devices • Check for the presence of circuit diagrams, manual & log book | |
| <i>Machinery</i> | <ul style="list-style-type: none"> • Check sheaves, pulleys and drums with special attention to the grooves • Check the condition and operation of the brake & the condition of the brake linings • Check the running of the lift machinery • Check condition of drive belts | |
| <i>Lift Well</i> | <ul style="list-style-type: none"> • Inspect and test any safety gear • Visual check of lift well enclosure • Check hoisting ropes for equal tension, attachments and terminations are correct and in good condition, number of broken wires within acceptable limits, fraying not being shed, all ropes of similar condition, correct length of rope • Visual check of guide rails for integrity, straightness and security • Check condition of guide shoes or rollers | |
| <i>Lift Pit</i> | <ul style="list-style-type: none"> • Check there are no obstructions or rubbish in the pit • Check that lighting in the lift pit functions. Check dryness of pit • Visual check of buffer condition and other lift components | |
| <i>Landing Stations</i> | <ul style="list-style-type: none"> • Check door locks • Check lift controls for correct operation | |
| <i>Lift Car</i> | <ul style="list-style-type: none"> • Check car doors or safety barriers • Check lift car lighting | |
| <i>Hydraulic Systems</i> | <ul style="list-style-type: none"> • Visual check of the hydraulic system, including hoses, ram and cylinder • Check caisson for moisture • Check operation of anti-creep device • Check the operation of control and auxiliary valves | |

Continued on next page

| | |
|-------------------|---|
| <i>Operation</i> | <ul style="list-style-type: none"> • Check operation of terminal stopping devices, slack rope switch and any emergency switch • Check landing door interlocks and opening of the door when the car is away from the landing |
| <i>General</i> | <ul style="list-style-type: none"> • Visual check for any repairs or modifications carried out incorrectly • Check maintenance records are properly kept • Where the system is connected to the building's emergency warning system, testing of the interface between the two systems. Check for correct operation under fire conditions • Check correct operation of counterweight displacement detector • Check operation of load weighting device |
| Reporting: | <p>The owner will keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. These will be recorded in the On-Site Log Book, which will remain on the premises with the most recent compliance schedule, and as a minimum include:</p> <ul style="list-style-type: none"> • Details of any inspection, test or preventative maintenance carried out, including dates, works undertaken, faults found, remedies applied and the person who performed the work. • Form 12A provided annually by the IQP |