

## **Appendix D: Water supply disinfection specification**

Where the specification in NZS4404:2010 and the Supplement document table conflict, precedence shall be given to NZS4404:2010.

**Add the following Note**

- D4** Note that the main must not be drained after flushing unless all high points are 'vented' to allow for complete removal of air.