

## **Compliance Schedule Details:**

## SS 2 – Automatic/Manual Emergency Warning Systems (Alarms)

Please provide the following information with your Building Consent Application - Form 2

(If you need help to complete this form, consult the system provider or an IQP who is registered for the system above)

( )			,	to registered for the dystem disever		
Applicant Name:			Installation provider: (ii	f known)		
Existing Compliance Schedule Number(s): (if applic		oplicable)	Risk / Purpose group: Fire Hazard Category:			
SPECIFIED SYSTEM DESCRIPTION (address those items that apply)						
Specified Existing New Modified systems:			noved			
Type:			arning System (SSWS)			
	☐ Monitored non-standard Securit	☐ Monitored non-standard Security Based Warning System (SBWS)				
	☐ Type 3: Automatic fire alarm sys☐ Type 4: Automatic fire alarm sys☐ Type 5: Automatic fire alarm sys☐ A carbon monoxide gas detection potentially hazardous concentration	<ul> <li>Type 2: Manual warning systems</li> <li>Type 3: Automatic fire alarm system with heat detectors and manual call points</li> <li>Type 4: Automatic fire alarm system with smoke detectors and manual call points</li> <li>Type 5: Automatic fire alarm system with modified smoke / heat detection and manual call points</li> <li>A carbon monoxide gas detection system within a car park building that warms occupants of a potentially hazardous concentration of gas</li> <li>Other: [specify]</li></ul>				
Response: (i.e. Warning)		□м	☐ Manual ☐ Automatic			
Supplementary Devices: (i.e. detection)		□н	☐ Heat Detectors ☐ Smoke Detectors ☐ Gas Detectors			
Alarm Interfacing: [specify e.g. SS1, SS3/3, SS9]						
Location	on Plan for specified systems and reco	ords is attac	ched: YES 1	NO		
No.	No. Equipment location Mak		components)	Model		
1						
2						
3						
4						
	<u> </u>	If needed continue the list on another sheet of paper				
STANDARDS (address those items that apply)						
Specifically, designed solutions do not apply if the system has been installed against a specific Standard(s) / document.  continue on the next page						

Performance /	NZS 4512:2010 Fire detection and alarm systems in buildings.				
installation:	□ NZS 4512:2003 Fire detection and alarm systems in buildings.				
	NZS 4512:1997 Fire alarm systems in buildings.				
	NZS 4512:1994 Fire alarm systems in buildings.				
	NZS 4512:1981 Automatic fire alarm systems in buildings				
	NZS 4514:2009 Interconnected smoke alarms for houses				
	NZS 4514:2002 Interconnected smoke alarms for single household units NZS				
	4514:1989 The installation of smoke alarms				
	☐ NZS 4561:1973 Specification for manual fire alarm systems for use in buildings				
	<ul> <li>□ NZS 4512:2021 Fire detection and alarm systems in buildings</li> <li>□ Specifically, designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided)</li> <li>□ Other</li> </ul>				
Inspections:	□ NZS 4512:2021 Part 6	☐ Specifically, designed solution prepared by a persol			
	☐ NZS 4512:2010 Part 6	who, on the basis of experience and qualifications, is competent to do so. (Details provided)			
	☐ NZS 4512:2003 Part 6				
	☐ NZS 4512:1997 Part 6				
	☐ NZS 4512:1981 Part 4				
Maintenance:	☐ NZS 4512:2010 Part 6	Specifically, designed solution prepared by a person who, on the basis of experience and qualifications,			
	☐ NZS 4512:2003 Part 6				
	is competent to do so. (Details provided)  NZS 4512:1997 Part 6				
	□ NZS 4512:1981 Part 4				
	□ NZS 4514:2009 Part 6				
	☐ NZS 4561:1973 Appendix A				
	☐ NZS 4512:2021 Part 6				
INSPECTIONS,	MAINTENANCE AND REPO	PRTING (address those items that apply)			
Minimum		ance and responsive maintenance will be carried out in accordance			
inspection and maintenance with the nominated performance and inspection Standard/document, to ensure the system operate as required in the event of a fire or other danger.					
procedures:	7				
Inspection frequency and	☐ Specifically designed	By IQP			
responsibility:	solutions				
	School Security Warning System (SSWS):	<ul> <li>Monthly: by School Representative</li> <li>Six Monthly: by Security Alarm maintenance contractor</li> <li>Annual:</li></ul>			
	Converte Poored Werning				
	Security Based Warning System (SBWS)				
		Annually:(sounders & smoke detectors + annual survey) by IQP			
		only			
	Manual warning systems	<ul> <li>Monthly: (Sounders) by IQP only</li> <li>Quarterly: (Sounders) by IQP only</li> <li>Annually: by IQP only</li> </ul> continue on the next page			
	(Type 2f alarm)				
ĺ		,			

	☐ Automatic fire alarm system (Type ☐ 3, ☐ 4, ☐ 5, ☐ 6, ☐ 7)	<ul><li>Monthly: (Sounders) by IQP only</li><li>Quarterly:(Sounders) by IQP only</li><li>Annually: by IQP only</li></ul>	
Reporting:	The owner will keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. These will be recorded in the On-Site Log Book, which will remain on the premises with the most recent compliance schedule, and as a minimum include:  • Details of any inspection, test or preventative maintenance carried out, including dates, works undertaken, faults found, remedies applied and the person who performed the work.  • Form 12A provided annually by the IQP		